



## Environmental and Laboratory Services

90 ½ West Blackwell St., Dover, New Jersey 07801

(973) 989-0010 P, (973) 989-0156 F

## Analytical Results

Date: June 20, 2016

Address: Boonton High School  
: 434 Lathrop Avenue  
Boonton, NJ 07005

Project: Craig High School Wing

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-1  
Sample location: Ladies Room Sink 1  
Sampled by: D. Diaz / V. Montanaro  
Sample date: 05/27/16  
Time: 07:12  
Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/02/16	19:16	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-2  
Sample location: Water Fountain  
Sampled by: D. Diaz / V. Montanaro  
Sample date: 05/27/16  
Time: 07:10  
Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/02/16	19:40	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-3  
Sample location: Custodial Closet  
Sampled by: D. Diaz / V. Montanaro  
Sample date: 05/27/16  
Time: 07:11  
Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	5.91 ug/L	15 ug/L	06/02/16	19:45	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-4  
 Sample location: Mens Room Sink 1  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 07:08  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/02/16	19:51	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-5  
 Sample location: Mens Room Sink 2  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 07:09  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/02/16	19:56	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-6  
 Sample location: Craig High School Office #2  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 07:15  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/02/16	20:02	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-7  
 Sample location: Field Blank  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 07:08  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/02/16	20:08	2 ug/L

#### Project: Main Floor

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-8  
 Sample location: Custodial Closet  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 09:06  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	2.30 ug/L	15 ug/L	06/02/16	20:13	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-9  
 Sample location: Girls Bathroom Sink 1  
 Sample date: 05/27/16  
 Time: 09:07  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/02/16	20:19	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-10  
 Sample location: Girls Bathroom Sink 2  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 09:08  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	2.10 ug/L	15 ug/L	06/02/16	20:36	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-11  
 Sample location: Girls Bathroom Sink 3  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 09:09  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/02/16	20:41	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-12  
 Sample location: Girls Bathroom Sink 4  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 09:10  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/02/16	20:47	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-13  
 Sample location: Kitchen Prep Area 1  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 10:24  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/02/16	20:53	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-14  
 Sample location: Kitchen Prep Area 2  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 10:25  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	05/13/16	20:58	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-15  
 Sample location: Kitchen 2 Compartment Sink  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 10:26  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/02/16	21:04	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-16  
 Sample location: Kitchen 3 Compartment Left Tap  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 10:27  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/02/16	21:10	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-17  
 Sample location: Kitchen 3 Compartment Right Tap  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 10:28  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/02/16	21:15	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-18  
 Sample location: Kitchen Coffee Sink  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 10:23  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/02/16	21:21	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-19  
 Sample location: Kitchen Custodial Closet  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 10:21  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	4.0 ug/L	15 ug/L	06/02/16	21:27	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-20  
 Sample location: Kitchen Bathroom  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 10:22  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/02/16	21:44	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-21  
 Sample location: Nurse Office Supply Room  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 09:01  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	114 ug/L	15 ug/L	06/02/16	22:17	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-22  
 Sample location: Nurse Office Handwash  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 09:02  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/02/16	22:23	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-23  
 Sample location: Nurse Office Bathroom  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 09:03  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/02/16	22:29	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-24  
 Sample location: Nurse Office Testing Room  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 09:04  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	7.55 ug/L	15 ug/L	06/02/16	23:34	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-25  
 Sample location: Guidance Suite Mens Room  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 08:58  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/02/16	22:40	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-26  
 Sample location: Guidance Suite Ladies Room  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 08:56  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/02/16	22:51	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-27  
 Sample location: Guidance Suite Water Fountain  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 08:57  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	2.24 ug/L	15 ug/L	06/02/16	22:56	2 ug/L

### Project: Gymnasium Wing

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-28  
 Sample location: Girls Locker Room Vestibule Water Fountain  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 10:15  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	7.12 ug/L	15 ug/L	06/07/16	16:58	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-29  
 Sample location: Boys Locker Room Sink 1  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 10:04  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/02/16	23:02	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-30  
 Sample location: Boys Coaches Office  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 10:03  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	3.44 ug/L	15 ug/L	06/02/16	23:13	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-31  
 Sample location: Trainers Room  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 10:06  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/02/16	23:19	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-32  
 Sample location: Boys Locker Room Vestibule Water Fountain  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 10:13  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	2.27 ug/L	15 ug/L	06/02/16	23:25	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-33  
 Sample location: Jock Hall Girls Room Sink 1  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 09:51  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	4.12 ug/L	15 ug/L	06/02/16	23:31	2 ug/L



Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-34  
 Sample location: Jock Hall Girls Room Sink 2  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 09:52  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	2.15 ug/L	15 ug/L	06/02/16	23:36	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-35  
 Sample location: Jock Hall Water Fountain by Girls Room  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 09:53  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/02/16	23:42	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-36  
 Sample location: Jock Hall Custodial Closet  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 10:00  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	3.68 ug/L	15 ug/L	06/02/16	23:48	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-37  
 Sample location: Jock Hall Boys Room Sink 1  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 10:09  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/03/16	15:16	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-38  
 Sample location: Jock Hall Boys Room Sink 2  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 10:10  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	3.08 ug/L	15 ug/L	06/03/16	15:21	2 ug/L



Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-39  
 Sample location: Jock Hall Water Fountain by Boys Room  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 10:02  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/03/16	15:27	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-40  
 Sample location: Girls Locker Room Sink 1  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 09:54  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/03/16	15:33	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-41  
 Sample location: Girls Locker Room Sink 2  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 09:55  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/03/16	15:36	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-42  
 Sample location: Girls Coaches Office  
 Sample date: 05/27/16  
 Time: 09:56  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/03/16	16:13	2 ug/L

#### Project: Auditorium Wing

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-43  
 Sample location: Boiler Room Sink  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 09:46  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/03/16	16:18	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-44  
 Sample location: Room 127 Art Room Sink 1  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 09:43  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	5.55 ug/L	15 ug/L	06/03/16	16:24	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-45  
 Sample location: Room 127 Art Room Sink 2  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 09:44  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	12.2 ug/L	15 ug/L	06/03/16	16:29	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-46  
 Sample location: Room 123 Photo Lab Sink 1  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 09:41  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	3.68 ug/L	15 ug/L	06/03/16	16:35	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-47  
 Sample location: Room 123 Photo Lab Sink 2 Dark Room  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 09:42  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/03/16	16:41	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-48  
 Sample location: Ladies BR and Adjoining Locker Room Sink 1  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 09:36  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/03/16	16:46	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-49  
 Sample location: Ladies BR and Adjoining Locker Room Sink 2  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 09:37  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/03/16	16:52	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-50  
 Sample location: Ladies BR and Adjoining Locker Room Sink 3  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 09:38  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/03/16	16:57	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-51  
 Sample location: Locker Room Water Fountain Left  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 09:35  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/03/16	17:03	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-52  
 Sample location: Locker Room Water Fountain Right  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 09:34  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	12.4 ug/L	15 ug/L	06/03/16	17:20	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-53  
 Sample location: Mens BR and Adjoining Locker Room Sink 1  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 09:29  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/03/16	17:25	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-54  
 Sample location: Mens BR and Adjoining Locker Room Sink 2  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 09:30  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/03/16	17:31	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-55  
 Sample location: Mens BR and Adjoining Locker Room Sink 3  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 09:31  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/03/16	17:37	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-56  
 Sample location: Custodial Closet  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 09:32  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	8.51 ug/L	15 ug/L	06/03/16	17:42	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-57  
 Sample location: Media Center Office  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 09:21  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	3.62 ug/L	15 ug/L	06/07/16	17:03	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-58  
 Sample location: Next To Room 117 Left Fountain  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 09:14  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/03/16	17:48	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-59  
 Sample location: Next To Room 117 Right Fountain  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 09:15  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/03/16	17:54	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-60  
 Sample location: Boys Bathroom Sink 1 Next To 117  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 09:17  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	6.30 ug/L	15 ug/L	06/03/16	17:59	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-61  
 Sample location: Boys Bathroom Sink 2  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 09:18  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	2.04 ug/L	15 ug/L	06/03/16	18:21	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-62  
 Sample location: Boys Bathroom Sink 3  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 09:19  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	2.66 ug/L	15 ug/L	06/03/16	18:38	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-63  
 Sample location: Girls BR Locker Room Handicap Sink  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 09:39  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	910 ug/L	15 ug/L	06/13/16	18:13	2 ug/L

**Project: 2<sup>nd</sup> Floor of Boonton High School**

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-64  
Sample location: Girls Bathroom Science Wing Sink  
Sampled by: D. Diaz / V. Montanaro  
Sample date: 05/27/16  
Time: 08:26  
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	7.60 ug/L	15 ug/L	06/03/16	18:44	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-65  
Sample location: Water Fountain Left  
Sampled by: D. Diaz / V. Montanaro  
Sample date: 05/27/16  
Time: 08:31  
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/03/16	18:49	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-66  
Sample location: Water Fountain Right  
Sampled by: D. Diaz / V. Montanaro  
Sample date: 05/27/16  
Time: 08:32  
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/03/16	18:55	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-67  
Sample location: Custodial Room  
Sampled by: D. Diaz / V. Montanaro  
Sample date: 05/27/16  
Time: 08:34  
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	3.60 ug/L	15 ug/L	06/03/16	19:01	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-68  
Sample location: Boys Bathroom Science Wing Sink 1  
Sampled by: D. Diaz / V. Montanaro  
Sample date: 05/27/16  
Time: 08:35  
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	4.16 ug/L	15 ug/L	06/03/16	10:47	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-69  
 Sample location: Boys Bathroom Science Wing Sink 2  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 08:36  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	5.73 ug/L	15 ug/L	06/03/16	11:11	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-70  
 Sample location: Room 218 Office Sink  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 08:12  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	48.5 ug/L	15 ug/L	06/03/16	11:17	2 ug/L

**Project: Main Floor**

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-71  
 Sample location: Main Office Copy Room  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 08:59  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/03/16	11:30	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-72  
 Sample location: Water Fountain Across From Front Office  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 08:53  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	3.87 ug/L	15 ug/L	06/03/16	11:36	2 ug/L



**Project: 2<sup>nd</sup> Floor of Boonton High School**

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-73  
Sample location: Room 223 Lab Sink 1 Right Tap  
Sampled by: D. Diaz / V. Montanaro  
Sample date: 05/27/16  
Time: 08:00  
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	14.3 ug/L	15 ug/L	06/07/16	17:27	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-74  
Sample location: Room 223 Lab Sink 2 Right Tap  
Sampled by: D. Diaz / V. Montanaro  
Sample date: 05/27/16  
Time: 08:01  
Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	27.4 ug/L	15 ug/L	06/03/16	11:45	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-75  
Sample location: Room 223 Lab Sink 3 Right Tap  
Sampled by: D. Diaz / V. Montanaro  
Sample date: 05/27/16  
Time: 08:02  
Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	6.84 ug/L	15 ug/L	06/03/16	11:58	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-76  
Sample location: Room 223 Lab Sink 4 Right Tap  
Sampled by: D. Diaz / V. Montanaro  
Sample date: 05/27/16  
Time: 08:03  
Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	20.8 ug/L	15 ug/L	06/03/16	12:04	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-77  
Sample location: Room 223 Lab Sink 5 Right Tap  
Sample date: 05/27/16  
Time: 08:04  
Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	23.0 ug/L	15 ug/L	06/03/16	12:14	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-78  
 Sample location: Room 223 Lab Sink 6 Right Tap  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 08:05  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	26.5 ug/L	15 ug/L	06/03/16	12:30	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-79  
 Sample location: Room 223 Lab Sink 7 Right Tap  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 08:06  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	19.4 ug/L	15 ug/L	06/03/16	12:36	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-80  
 Sample location: Room 223 Lab Sink 8  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 08:07  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	22.7 ug/L	15 ug/L	06/03/16	12:46	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-81  
 Sample location: Girls Bathroom Science Wing Sink 1  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 08:27  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	4.28 ug/L	15 ug/L	06/03/16	12:52	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-82  
 Sample location: Girls Bathroom Science Wing Sink 2  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 08:28  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	13.5 ug/L	15 ug/L	06/03/16	13:05	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-83  
 Sample location: Room 216  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 07:39  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	4.44 ug/L	15 ug/L	06/03/16	13:11	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-84  
 Sample location: Room 218 Lab Sink 1 Right Tap  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 08:13  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	15.2 ug/L	15 ug/L	06/03/16	13:18	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-85  
 Sample location: Room 218 Lab Sink 2 Right Tap  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 08:14  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	23.2 ug/L	15 ug/L	06/03/16	13:25	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-86  
 Sample location: Room 218 Lab Sink 3  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 08:15  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	80.5 ug/L	15 ug/L	06/03/16	13:44	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-87  
 Sample location: Room 218 Lab Sink 4 Right Tap  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 08:16  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	11.5 ug/L	15 ug/L	06/03/16	13:50	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-88  
 Sample location: Room 218 Lab Sink 5 Right Tap  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 08:17  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	13.2 ug/L	15 ug/L	06/03/16	14:09	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-89  
 Sample location: Room 218 Lab Sink 6 Right Tap  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 08:18  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	14.8 ug/L	15 ug/L	06/03/16	14:33	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-90  
 Sample location: Room 218 Lab Sink 7 Right Tap  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 08:19  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	13.4 ug/L	15 ug/L	06/03/16	14:39	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-91  
 Sample location: Room 218 Lab Sink 8  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 08:20  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	5.51 ug/L	15 ug/L	06/03/16	14:45	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-92  
 Sample location: Room 219  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 07:38  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	2.67 ug/L	15 ug/L	06/03/16	14:52	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-93  
 Sample location: Room 221 Office Sink  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 07:51  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	141 ug/L	15 ug/L	06/03/16	15:07	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-94  
 Sample location: Room 221 Lab Sink 1 Right Tap  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 07:43  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	51.8 ug/L	15 ug/L	06/03/16	15:19	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-95  
 Sample location: Room 221 Lab Sink 2 Right Tap  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 07:44  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	37.8 ug/L	15 ug/L	06/03/16	15:35	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-96  
 Sample location: Room 221 Lab Sink 3  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 07:45  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	71.6 ug/L	15 ug/L	06/03/16	15:47	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-97  
 Sample location: Room 221 Lab Sink 4 Right Tap  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 07:46  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	30.2 ug/L	15 ug/L	06/03/16	16:02	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-98  
 Sample location: Room 221 Lab Sink 5 Right Tap  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 07:47  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	21.1 ug/L	15 ug/L	06/03/16	16:15	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-99  
 Sample location: Room 221 Lab Sink 6 Right Tap  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 07:48  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	27.0 ug/L	15 ug/L	06/03/16	16:25	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-100  
 Sample location: Room 221 Lab Sink 7 Right Tap  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 07:49  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	35.6 ug/L	15 ug/L	06/03/16	16:34	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-101  
 Sample location: Room 221 Lab Sink 8  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 07:50  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	37.2 ug/L	15 ug/L	06/03/16	16:44	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-102  
 Sample location: Room 223 Office Sink  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 07:57  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	708 ug/L	15 ug/L	06/13/16	18:20	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-103  
 Sample location: Child Study Mens Room  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 07:22  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	3.77 ug/L	15 ug/L	06/03/16	16:51	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-104  
 Sample location: Child Study Ladies Room  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 07:23  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	13.9 ug/L	15 ug/L	06/03/16	16:57	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-105  
 Sample location: Child Study Conference Room  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 07:24  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	3.06 ug/L	15 ug/L	06/03/16	17:04	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-106  
 Sample location: Boys Bathroom Next to Room 202 Sink 1  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 07:27  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	5.57 ug/L	15 ug/L	06/03/16	17:16	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-107  
 Sample location: Custodial Closet Room 202  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 07:29  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/02/16	17:22	2 ug/L



Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-108  
 Sample location: Water Fountain Across Room 204  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 07:31  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/03/16	17:34	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-109  
 Sample location: Girls Bathroom Sink 1  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 07:33  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/03/16	17:58	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-110  
 Sample location: Room 208 Sink 1  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 07:35  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	2.13 ug/L	15 ug/L	06/03/16	18:04	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS3079-111  
 Sample location: Room 208 Sink 2  
 Sampled by: D. Diaz / V. Montanaro  
 Sample date: 05/27/16  
 Time: 07:36  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	2.66 ug/L	15 ug/L	06/03/16	18:10	2 ug/L

ug/L = micrograms per liter

Notes:

DWS3079-1: Slow drip.

DWS3079-102: Air in water line.

All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan VanVeen  
 Susan VanVeen, Lab Manager  
 NJ Laboratory Certification ID # 14013

6/20/16  
 Date