



Garden State Laboratories, Inc.

Report Date: 04/29/2022

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gsllabs.com
Internet: www.gsllabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A. Laboratory Manager

For: Boonton Public Schools - NW
434 Lathrop Ave

Boonton, NJ 07005

Laboratory Director:

Attention: Jerry Bello

Client Number: BOO10

Sample ID: BOONHS-21-1 BF by Gym Lab Sample ID: 220422049-01
Site: Collection Date/Time: 04/22/2022 08:00
Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	0.0117 mg/l	0.015	0.00100	0.00055	20044	04/27/22 23:21	

Sample ID: BOONHS-21-2 Ice Machine Trainer Lab Sample ID: 220422049-02
S. Collection Date/Time: 04/22/2022 08:01
Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/27/22 23:24	

Sample ID: BOONHS-21-3 Sink Trainers Lab Sample ID: 220422049-03
Site: Collection Date/Time: 04/22/2022 08:01
Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/27/22 23:27	



Sample ID: BOONHS-21-4 BF by 104 Lab Sample ID: 220422049-04
 Site: Collection Date/Time: 04/22/2022 08:02
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/27/22 23:29	

Sample ID: BOONHS-21-5 BF by Main Off Lab Sample ID: 220422049-05
 Site: Collection Date/Time: 04/22/2022 08:03
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/27/22 23:44	

Sample ID: BOONHS-21-6 Sink Main Office Lab Sample ID: 220422049-06
 Site: Collection Date/Time: 04/22/2022 08:04
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/27/22 23:47	

Sample ID: BOONHS-21-7 Sink Faculty Rm Lab Sample ID: 220422049-07
 Site: Collection Date/Time: 04/22/2022 08:05
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/27/22 23:56	

Sample ID: BOONHS-21-8 Sink Kitchen Cent Lab Sample ID: 220422049-08
 Site: Collection Date/Time: 04/22/2022 08:06
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/27/22 23:59	



Sample ID:	BOONHS-21-9 Sink Kitchen by Oven		Lab Sample ID:	220422049-09					
Site:			Collection Date/Time:	04/22/2022 08:06					
Matrix:	Potable water		Sample Type:	Grab					
Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/28/22 00:02	

Sample ID:	BOONHS-21-10 B/F by 117		Lab Sample ID:	220422049-10					
Site:			Collection Date/Time:	04/22/2022 08:07					
Matrix:	Potable water		Sample Type:	Grab					
Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/28/22 00:05	

Sample ID:	BOONHS-21-11 W/F by 117		Lab Sample ID:	220422049-11					
Site:			Collection Date/Time:	04/22/2022 08:07					
Matrix:	Potable water		Sample Type:	Grab					
Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/28/22 00:08	

Sample ID:	BOONHS-21-12 Sink in Library		Lab Sample ID:	220422049-12					
Site:			Collection Date/Time:	04/22/2022 08:09					
Matrix:	Potable water		Sample Type:	Grab					
Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/28/22 00:16	

Sample ID:	BOONHS-21-13 BF by Auditorium		Lab Sample ID:	220422049-13					
Site:			Collection Date/Time:	04/22/2022 08:10					
Matrix:	Potable water		Sample Type:	Grab					
Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/28/22 00:19	



Sample ID: BOONHS-21-14 Sink Nurses Lab Sample ID: 220422049-14
 Site: Collection Date/Time: 04/22/2022 08:11
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	0.00163 mg/l	0.015	0.00100	0.00055	20044	04/28/22 00:22	

Sample ID: BOONHS-21-15 B/F By 223 Lab Sample ID: 220422049-15
 Site: Collection Date/Time: 04/22/2022 08:13
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/28/22 00:25	

Sample ID: BOONHS-21-16 Sink H E left Lab Sample ID: 220422049-16
 Site: Collection Date/Time: 04/22/2022 08:13
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/28/22 00:28	

Sample ID: BOONHS-21-17 Sink H E right Lab Sample ID: 220422049-17
 Site: Collection Date/Time: 04/22/2022 08:14
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/28/22 00:31	

Sample ID: BOONHS-21-18 B/F by 203 Lab Sample ID: 220422049-18
 Site: Collection Date/Time: 04/22/2022 08:15
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/28/22 00:33	



Sample ID:	BOONHS-21-19 Sink Faculty 2nd		Lab Sample ID:	220422049-19					
Site:			Collection Date/Time:	04/22/2022 08:17					
Matrix:	Potable water		Sample Type:	Grab					
Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/28/22 00:36	

Sample ID:	BOONHS-21-20 Sink Concession		Lab Sample ID:	220422049-20					
Site:			Collection Date/Time:	04/22/2022 08:21					
Matrix:	Potable water		Sample Type:	Grab					
Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/28/22 01:04	

Sample ID:	BOONHS-21-21 Field Blank		Lab Sample ID:	220422049-21					
Site:			Collection Date/Time:	04/22/2022 08:22					
Matrix:	Potable water		Sample Type:	Grab					
Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/28/22 01:07	

DF=Dilution factor; <=less than, MCL=Maximum Contaminant Level, Rep. Limit=Reporting Limit and MDL=Method Detection Limit.
 The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
 When sample is collected by Garden State Labs, it is taken in accordance with the most current Field Sampling Plan GSL.FS.
 Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

