



Garden State Laboratories, Inc.

Report Date: 04/28/2022

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A. Laboratory Manager

For: Boonton Public Schools - NW
434 Lathrop Ave

Boonton, NJ 07005

Laboratory Director:

Attention: Jerry Bello

Client Number: BOO10

Sample ID: BOON Pres - 21 -1 Sink
Front Rm
Lab Sample ID: 220422046-01
Site: Collection Date/Time: 04/22/2022 07:49
Matrix: Potable water
Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/26/22 20:09	

Sample ID: BOON Pres - 21 - 2 Sink
Rear Room
Lab Sample ID: 220422046-02
Site: Collection Date/Time: 04/22/2022 07:49
Matrix: Potable water
Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/26/22 20:12	

Sample ID: BOON Pres - 21 - 3 Field
Blank
Lab Sample ID: 220422046-03
Site: Collection Date/Time: 04/22/2022 07:50
Matrix: Potable water
Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/26/22 20:14	

DF=Dilution factor; <=less than, MCL=Maximum Contaminant Level, Rep. Limit=Reporting Limit and MDL=Method Detection Limit.
The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with the most current Field Sampling Plan GSL.FS.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

