



Garden State Laboratories, Inc.

Report Date: 04/28/2022

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gsllabs.com
Internet: www.gsllabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A. Laboratory Manager

For: Boonton Public Schools - NW
434 Lathrop Ave

Boonton, NJ 07005

Attention: Jerry Bello

Laboratory Director:

Client Number: BOO10

Sample ID: BOONJH - 21- 1 BF by
Office

Lab Sample ID: 220422047-01

Site: Collection Date/Time: 04/22/2022 07:30

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/26/22 20:17	

Sample ID: BOONJH - 21- 2 Bubbler Rm
B 120

Lab Sample ID: 220422047-02

Site: Collection Date/Time: 04/22/2022 07:32

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/26/22 20:20	

Sample ID: BOONJH - 21- 3 Bubbler Rm
B 119

Lab Sample ID: 220422047-03

Site: Collection Date/Time: 04/22/2022 07:32

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/26/22 20:29	



Sample ID:	BOONJH - 21- 4 Bubbler Rm B 118		Lab Sample ID:	220422047-04					
Site:			Collection Date/Time:	04/22/2022 07:33					
Matrix:	Potable water		Sample Type:	Grab					
Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/26/22 20:32	

Sample ID:	BOONJH - 21- 5 B/F by A- 102		Lab Sample ID:	220422047-05					
Site:			Collection Date/Time:	04/22/2022 07:35					
Matrix:	Potable water		Sample Type:	Grab					
Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/26/22 20:35	

Sample ID:	BOONJH - 21- 6 Sink Faculty		Lab Sample ID:	220422047-06					
Site:			Collection Date/Time:	04/22/2022 07:35					
Matrix:	Potable water		Sample Type:	Grab					
Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/26/22 20:37	

Sample ID:	BOONJH - 21- 7 Sink Kitchen Center		Lab Sample ID:	220422047-07					
Site:			Collection Date/Time:	04/22/2022 07:36					
Matrix:	Potable water		Sample Type:	Grab					
Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/26/22 20:40	

Sample ID:	BOONJH - 21- 8 Sink Kitchen Vegetable		Lab Sample ID:	220422047-08					
Site:			Collection Date/Time:	04/22/2022 07:36					
Matrix:	Potable water		Sample Type:	Grab					
Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/26/22 20:43	



Sample ID:	BOONJH - 21- 9 Sink Kitchen by wall		Lab Sample ID:	220422047-09					
Site:			Collection Date/Time:	04/22/2022 07:37					
Matrix:	Potable water		Sample Type:	Grab					
Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/26/22 20:46	

Sample ID:	BOONJH - 21- 10 RF by A 203		Lab Sample ID:	220422047-10					
Site:			Collection Date/Time:	04/22/2022 07:39					
Matrix:	Potable water		Sample Type:	Grab					
Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/26/22 20:49	

Sample ID:	BOONJH - 21- 11 BF by A 302		Lab Sample ID:	220422047-11					
Site:			Collection Date/Time:	04/22/2022 07:40					
Matrix:	Potable water		Sample Type:	Grab					
Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/26/22 20:52	

Sample ID:	BOONJH - 21- 12 Sink Nurses		Lab Sample ID:	220422047-12					
Site:			Collection Date/Time:	04/22/2022 07:41					
Matrix:	Potable water		Sample Type:	Grab					
Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/26/22 20:55	

Sample ID:	BOONJH - 21- 13 Field Blank		Lab Sample ID:	220422047-13					
Site:			Collection Date/Time:	04/22/2022 07:42					
Matrix:	Potable water		Sample Type:	Grab					
Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/26/22 21:09	

DF=Dilution factor; <=less than, MCL=Maximum Contaminant Level, Rep. Limit=Reporting Limit and MDL=Method Detection Limit.
The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with the most current Field Sampling Plan GSL.FS.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.



